

Our mission at US Draft Co. is to develop leading edge technology for the heating appliance and fireplace venting industries. With over 25 combined years of experience, available, US Draft Co. has developed a full line of mechanical

EC-Flow[™] technology and Truline[™] fan construction, US Draft Co. is solving the venting challenges of appliances. At US Draft Co., we presented in modern day appliance

	minet Dee		Propert I	Name: Y	our Project				Applian	ce Input Data	
97 P	гојест кер	ort	Project.	Fori			Mex In	IN CHERO	1197	CO2% in Flue Gas	e 9.2
v			Compar	¥.			Min big	(HBH) 5.4	798	Ambient Tem	0 75
Dity: Po	et Worth						Manima	um Denni	200	ARRight (TL)	500
Date: TX	£						Ter	10 (7)			-
WallType:	2 Can	ngory:	4	Puel Ty	ge 1		Minimum Gross Temp (P)		160	Exhaust Allowable Pressure Rang	0.3 % 0.
	Combustion Re	of Information					-	and Partness	-		
Total Durt	15	15 Dennie Elber			-					-	
Length:					Length (R)		94		Decisies .		
WHE Tee		30 Degree Ellio			Tatal Horizontal		38	30 0	egree bow	0	
ID Degree Tee		45 Degree Elbo		8	Longth 90 Degree T	-	2	45.0	epre	0	
Lateral 45 Degree Tee		90 Cegree Ebo	**	2	Boot Tee		0	901	toowi Nogree		
sonaser Karige	010-0	Robucar Kange	• •	10.0	Inline Dran	n	1	Reduc	or Range	0.00.0	
Additional Presiure Loss		Inist Type		2	Increaser Range		0 10 0				
Existing Diameter	8	Combustion Air Requirements			Representation		0	8ath	- Open	0	
Contraction Air Adowable Pressure 0 to 0					Terroration Type		4	Add	tional ance (N)	0	
			Existing Dismeter		6	Additional Pressure Loss		0			
					and the second second	-					
		. Discuster		Cal	culation Rea	uite				Total	Tananata
		Diameter	CFH	Velocity	Density	1	Intel K Value	Pressure	Draft	Total Pressure	Temperatur
		Diameter	CPH	Velocity	Density	1	lotal K Value	Pressure	Draft	Total Pressure	Temperatur
contraction A	ir Resulta	Diameter	CFH 286	Velocity	Density	1	Intel K Value	Pressure	Draft	Total Pressure	Temperatur
orduntion A lar Sciected	ir Resulta Plac Inpu	Diameter	CFH 296	Velocity 9 845	Density	1 5.2	utal K Value	Pressure Loss	Draft Ng.R.	Total Pressure	Temperatur 70
conducation A lar Solution imputer Soler	ir Resulta Plac Inpu tedi Plac Dipu	Diameter 8 8 8 8	сян 296 296	9 845 845	Density 072 072	1	utal K Value	Pressure Loss 478 478	Draft NJA NJA	Total Pressure .078 .078	Temperatur 70 70
perduation A ter Solician imputer Solici	ir Resulta Plac lips ted) Plac lips	Diameter	CFM 295 295	Velocity 9 845 845	AUT2	5.2	latad K Value	Pressure Loss 878 878	Draft NJA NJA	Total Pressure .078	Temperatur 70 70
continuation A lar Solicited imputer Solic continuation A lar Solicited	ir Revulta Plex Irps tedi Ples Irps ir Connector Res	Diameter 1 8 1 8 1 8	CPH 296 296	Velocity 9 845 845	072	5.2	value	Pressure Loss 878 878	Draft NJA.	Total Pressure .078 .078	Temperatur 70 70 70
Combustion A Arr Sciected Combustion A Arr Selected Inhoust Resul	er Results Plac Inpu Ital Plac Inpu ir Connector Resu	Diameter	слн 296 296 395 слн	Velocity 9 845 845 1096 Velocity	072 072 072 Density	52 52	what K	Pressure Loss 878 875 875	Draft NEA NEA Draft	Total Pressure .000 .008 .05 Total	Temperatur 70 70 70 70
Continuation A An Solecled Continuation A An Solecled Continuation A	ir Results First inpu tell Plas inpu ir Connector Resu Re	Diameter	слн 296 296 95 слн	Velocity 9 845 845 1095 Velocity	072 072 072 072	1 5.2 5.2 1.2 1.2	istat K Value	Pressure Loss 878 878 878 878 878 878 878 878 878 8	Draft NUL NUL Draft	Total Pressure 508 508 505 705 Total Pressure	Temperatur 70 70 70
continuation A lier Solected contraction A ter Solected scheuett Research wer Solected	ir Results Pier Inpu Indi Pier Inpu ir Connector Res Re Pier Inpu	Diameter I II III III III III III III III III	сли 296 296 95 сли 314.696	Can Velocity 9 845 845 1355 Velocity 1862,737	0.020	3.2 3.2 12	Walue Value Walue 106	Pressure Loss 375 375 45 Pressure Loss 1.311	0-s48	Total Pressure 508 508 05 Total Pressure 2.499	Temperatur 70 70 Temperatur 120.48
Combustion A Aur Scholard Combustion A Aur Scholard Schoutin Aur Scholard Aur Scholard	ir Results Miss Ingu Ital Miss Ingu ir Connector Rass Its Miss Ingu Miss Ingu	Diameter 1 8 0 8 0 9 0 1 0 6	сли 296 296 35 сли 314.696 297.063	Can Velocity 9 845 845 1356 Velocity 1802,737 3203,735	072 072 0.000 0.000 0.000	312 312 12	wlad K Value Wlad K Value 426	Pressure Loss 475 475 475 475 475 475 475 475 475 475	Draft No.8. No.8. Draft Draft D.042 D.042	Total 97888000 4070 4070 4070 4070 4070 4070 4070 4070 4070 4070 4070 5070 1070	Temperatur 70 70 70 70 120 131.584
Combustion A Arr Solected Combustion A Arr Solected Scheust Reput Arr Solected	er Results Plac Inpu ted Plac Inpu in Connector Resu Re Plac Inpu Plac Inpu ted Plac Inpu	Diameter 1 8 6 8 0 0 1 6 1 6 1 6 2.8 1.8	сли 296 296 95 сли 314.696 314.696	Cas Velocity 9 845 845 1055 Velocity 1002.735 940.365	0.003 0.003 0.003 0.003	32 52 52 52 52 52 52 52 52 52 52 52 52 52	what R Value what K Value 106 105 12	Pressure Loss 475 475 475 475 475 455 1.535 1.535 0.663 0.467	Draft N/A N/A Draft Draft 0.052 0.052	Total 008 008 009	Temperatar 70 70 Temperatar 135.48 131.584 161.34
ionthuation A ter Selected imputer Selec ionthuation A ter Selected advant Reset ter Selected umputer Selec	er Results Plac Inpu tedl Plac Inpu ir Connector Res Re Plac Inpu Min Input Mex Inpu Min Input Mex Inpu	Diameter 1 8 1 8 10 8 10 8 10 10 11 10 12 10 13 10 14 10 15 10 16 10 17 10 18 10 19 10 10 10	сли 296 296 95 сли 314.696 314.696 314.696	Cas VeliceRy 9 845 1056 VeliceRy 1802.737 1003.735 1403.455	0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	3.2 3.2 12. 13. 13. 13. 13. 13. 13. 13. 13. 13. 13	what R Value Walue 436 435 122 54	Pressure Loss 275 275 255 1255 1255 1255 1255 1255 12	Draft N/A N/A N/A Draft Draft 0.052 0.052 0.052 0.052 0.052 0.052	Total 0200 0200	Temperatur 70 70 Temperatur 131:504 161:34 129:692
Combustion A Are Selected Insputer Selec Combustion A Are Selected Are Selected Are Selected Are Selected	ar Results Pics Inpu ar Connector Res ar Conn	Diameter 1 8 8 8 8 8 8 8 8 8 9 0 10 0 1 6 1 2.8 1 7.3	сли 296 236 95 сли 314.696 297.063 297.063	Cas Vulocity 9 845 845 1056 Velocity 1402,737 1303,735 948,365 393,825	0.009 0.009 0.009 0.009	3.2 5.2 5.2 12 12 13. 12	Watur R Value Value 426 925 12 54	Pressure 3078 3078 3078 3078 3078 3078 3078 3080 3080	Draft N/A N/A N/A Draft 0.062 0.053 0.062 0.053	Total 070	Temperatur 70 70 70 70 70 70 70 70 70 70 70 132,40 131,304 161,34 129,072
Derifuetion A for Solected onguter Sole ber Solected wer Solected wer Solected anguter Sole wer Solected wer Solected wer Solected	ar Results Max Trps ted Pice Trps ar Connector Res ar Connector Res for Trps for Trps Max Trps Max Trps Max Trps max Tres	Diameter 1 8 1 2 8 0 0 0 0 0 0 0 0 0 0 0 0 0	сян 296 296 35 сян 314.896 314.896 314.696 397.983	Cas Volkecity 9 845 845 1056 Volkecity 1002.737 548.365 393.325	0.005 0.005 0.005 0.005 0.006 0.006	312 112 112	wlaf K Value Value 196 995 12 54	Pressure Loss 478 479 479 479 479 1.311 0.463 0.463 0.463 0.225	Draft No. No. No. No. No. No. No. No. No. No.	Total 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0 0/0	Temperatur 70 70 120.40 131.504 166.34 120.692
confluention A lon fluention A confluention A confluention A confluention A schedult A schedult A confluention	in Results Net Days Plet Days in Connector Asso Re Plet Days Plet Days Plet Days Plet Sept Plet Sept Plet Sept Plet Sept Plet Sept	Diameter i n	сян 296 296 35 сян 314.896 314.896 314.696 297.983	Cas Velocity 9 845 845 1056 Velocity 1002.737 1003.735 946.365 1202.653	0.000 Penality 0.072 0.000 0.000 0.000 0.000 0.000 0.000	3.2 5.2 5.2 12 13. 13. 13. 13. 14. 15. 15. 15. 15. 15. 15. 15. 15. 15. 15	total R Value votal K Value 496 995 54 54	Pressure 30% 32% 45% 1.3% 0.4% 0.4% 0.2%	Draft No.A. No.A. No.A. Draft 0.052 0.053 0.053 0.053 0.053	Total 078 078 078 079 05 Total Pressure 1.79 0.171 0.172 0.174 0.174	Temperatur 70 70 120.40 131.564 164.34 156.32
continuation A ter Scinctoll continuetion A ter Scinctoll schaust Resea ter Scinctoll anguter Scinc schaust Cohn ter Scinctoll	ar Results Max logic Fac boy for Connector Resu Re Max logic Max logic Max logic Max logic Max logic Max logic Max logic	Diameter i n i n i n is is is Diameter i 0 i 0 i 0 i 0 i 0 i 0.009 i 0.009	сли 296 296 296 314.596 297.083 314.696 297.083 297.083 98.541	Cas Velocity 9 845 845 1056 Velocity 1002.737 1003.755 945.365 1923.526 1302.653 1128.265	0.000 Penality 0.072 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000 0.000	3.2 5.2 5.2 12 12 12 13 12 13 14 14 14 14 14 14 14 14 14 14 14 14 14	Initial K Value Initial K Value 195 195 195 195 195 195 195 195 195 195	Pressure 30% 37% 32% 48% 1.3% 0.4% 0.2% 0.2% 0.3% 0.3%	Draft No.4 No.5 Doraft	Total Pressure 000 0.008 001 0.008 005 Total Pressure 8.409 8.172 8.435 8.174 8.475 8.172	Temperatur 70 70 120,40 131,504 166,34 120,632 154,5 154,5
Continuation A Are Solution Continuation A Are Solution Inhoust Result Are Solution Inhoust Control Inhoust Control	or Results Pice Input Pice I	Diameter 1 8 1 8 1 8 1 0 1 0 1 0 1 0 1 0 2 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0.000	CFM 296 296 35 CFM 314.696 207.083 314.696 207.083 314.696 997.083 905.41	Cas Velocity 9 845 045 1005 1000,737 1000,735 946,365 1003,505 1202,653 1139,200	0.072 0.072 0.073 0.066 0.099 0.066	1 5.2 5.2 5.2 12 12 12 12 13 12 13 12 13 14 15 15 15 15 15 15 15 15 15 15 15 15 15	total K Value Value 196 197 122 122 124 144 144 147 144 147 144 147 144 147 147	Pressur 278 278 278 285 Pressur 1.588 0.483 0.487 0.225 0.188 0.3	Draft No.4 No.5 Draft Draft Draft Draft Draft Draft Draft Draft Draft	Total Pressure 070 070 070 070 070 070 070 070 070 070 070 070 070 070 070 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.07 0.172 0.3	Temperatur 70 70 Temperatur 1370-00 111.584 129.092 154.1 129.092
Combastion A Are Selected Computer Selected Combastion A Are Selected Debast Result Are Selected Inhard Communication Inhard Communication Are Selected	er Results Mar Dys. Mar Dys.	Diameter 0 N 0 N 0 N 0 Diameter 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0	C7M 226 226 226 226 227 224 226 227 224 226 227 224 226 227 224 226 226 226 226 226 226 226 226 226	Cas Vullocity 9 845 1096 Velecity 1802.737 1003.736 946.365 193.506 1202.053	0.023 0.023 0.023 0.006 0.006 0.006 0.006	32 32 12 12 13 13 14 14 14 14 14 14 14 14 14 14 14 14 14	utat K Value 496 995 122 54 64 62	Pressur Loss 478 478 485 Pressur 1,388 0,480 0,487 0,225 0,188 0,3	Draft No.8, Sq.8, Sq.8, Draft 0.062 0.052 0.052 0.052 0.052 0.053 0.055	Total Pressure .070 .070 .070 .070 .070 .070 .070 .070 .070 .070 .070 .070 .070 .070 .071 .072 .073 .074 .075 .070 .071 .072 .072 .073	Temperatur 70 70 Temperatur 129,40 111,564 116,34 129,072 154,1 123,30

US Draft Co. maintains a strong tie to American ingenuity and integrity. Our products are



US Draft Co. A Division of RM Manifold Group, Inc. 220 S. Sylvania Avenue, Suite 207, Fort Worth, TX 76111 Phone: 817-393-4029 Fax: 866-903-5771 www.usdraftco.com





Draft. Control. Solutions.

DRAFT CONTROL SYSTEM

The Draft Control System is designed to optimize the appliances' operating efficiencies by maintaining a constant pressure in the common manifold throughout the firing cycle. The Draft Control System employs a mechanical draft fan or damper-actuator with EC-Flow™ Technology a fully modulating, pressure-based VIC or mVIC control. Both the VIC and mVIC are programmable and designed to interlock with up to four appliances. The VIC is as also designed to interface with the building management system via a Modbus gateway. Mechanical draft fans: CB, TRV, and T9F. Damper-actuator: OBD. Controls: VIC, mVIC, XB

SUPPLY AIR SYSTEM

The Supply Air System is designed to supply the proper amount of fresh air to a mechanical room or laundry room. Commonly overlooked, an insufficient supply of fresh air can cause fossil fuel-fired heating appliances as well as clothes dryer to operate improperly, potentially damaging the appliance. The Supply Air System utilizes EC-Flow[™] Technology to maintain a field-determined room or duct pressure. The Supply Air System may interlock with up to eight appliances when used in conjunction with the XB expansion board. Supply fans: ISAB, ISAF, and WSAF. Controls: VIC, mVIC, ARB, and XB.

CLOTHES DRYER EXHAUST SYSTEM

The Clothes Dryer Exhaust System exhausts residential and/or commercial clothes dryers. Clothes dryer exhaust is one of the most difficult exhaust systems to design in a building due to lint-laden air and lack of buoyancy. The Clothes Dryer Exhaust System utilizes EC-Flow™ Technology to maintain a slight negative pressure in the exhaust manifold or shaft (for multi-story applications). The Clothes Dryer Exhaust System simulates that clothes dryers are individually exhausted by easing the back pressure in the common duct or riser and, in turn, allowing the dryer to operating more efficiently, lowering the drying time of the clothes. Properly designed and installed, the Clothes Dryer Exhaust System will reduce the owner's energy costs, saving money, while safely exhausting the connected clothes dryers. Exhaust fan: T9F. Controls: VIC, mVIC, ARB, and XB.

FIXED SPEED CONTROL

The Fixed Speed Control is designed to operate a mechanical draft fan at a fixed volume. The Fixed Speed Control utilizes the ARB draft control to interlock the fan with the appliance and sequence the system properly. The Fixed Speed Control is simple to install and can greatly increase the vent lengths of the installed heating equipment. Mechanical draft fans: CB, TRV, and T9F. Controls: XB.

HEARTH EXHAUST SYSTEM

Design to properly draft a wood- or gas-burning fireplace, the Hearth Exhaust System consists of the mechanical draft fan and the Universal Fan Control (UFC). With today's tighter construction, fireplaces cannot vent naturally due to the lack of make-up air. The use of mechanical draft also ensures that the fireplace's chimney does not become a supply duct for the home or building's exhaust or ventilation systems. Utilizing patent pending technology, the UFC takes advantage of the high efficiency synchronous motor to control the draft on the fireplace. The UFC can determine if the motor has failed and activates a visual and audible signal in case of fan failure as required by NFPA 211 and IMC. Chimney fans: CB, TRV, and T9F. TRV and T9F are suitable for listed gas-burning fireplaces only.



CB – TERMINATION CHIMNEY FAN

- Listed and conforms to UL standard 378 Type 1 & 2 and UL standard 705
- Upblast design to exhaust the flue gas away from the building
- Vertical or sidewall mounting

TRV – INLINE DRAFT INDUCER

- Listed and conforms to UL standard 378 Type 1 and UL standard 705
- Patent pending Truline[™] design for easy straight inline installation
- Rated for indoor or outdoor use

- Variable speed direct drive
- High efficiency electronically commutated motor
- FH model rated up to 1000°F continuous operation
- Variable speed direct drive
- High efficiency electronically commutated motor
- Rated up to 575°F continuous operation

T9F – TRUE 90° DRAFT INDUCER

- Listed and conforms to UL standard 378 Type 1 and UL standard 705
- Patent pending Truline[™] design, fits in place of an elbow without an offset
- Rated for indoor or outdoor use

OBD – OPPOSED BLADE DAMPER

- Multi-blade opposed blade damper
- Available in 304 stainless steel or 316 stainless steel
- Rated for indoor or outdoor use

ISAB/ISAF - INLINE SUPPLY FAN

- Truline[™] inline construction
- Backward curved motorized impeller
- · Variable speed electronically commutated motor

WSAF – WALL MOUNT SUPPLY AIR FAN

- Designed to mount indoors on the wall
- Premium efficiency axial motorized impeller
- · Variable speed electronically commutated motor

VIC - CONSTANT PRESSURE CONTROL

- Designed with EC-Flow™ technology
- Maintains a constant pressure for increased efficiency and proper operation
- Bi-directional pressure transducer for precise operation

mVIC- CONSTANT PRESSURE CONTROL

- Designed with EC-Flow[™] technology
- Maintains a constant pressure for increased efficiency and proper operation
- Bi-directional pressure transducer for precise operation

ARB – FIXED SPEED CONTROL

- Designed to operate a fan and damper
- Maintains a constant volume for proper appliance operation
- 24VDC supply for optional equipment

UFC - UNIVERSAL FAN CONTROL

- Designed for heating appliances and wood or gas fireplaces
- Integrated motor fault detection
- Damper relay for fireplaces

CGM – CARBON MONOXIDE SENSOR

- Designed to interlock with gas heating appliances
- Replaceable CO Sensor
- · Interlocks up to two appliances

- Variable speed direct drive
- Premium efficiency motor
- Rated up to 600°F continuous operation
- Fully modulating programmable actuator
- Modbus communication
- Rated up to 500°F standard operation, 750°F high temperature option
- ISAF models include 1" fiber insulation for quiet operation
- Rated up to 140°F standard operation
- Optional back draft damper
- · Listed and conforms to UL standard 705
- Interlocks up to four appliances
- Large visual display with keypad
- Listed to UL508
- Interlocks up to two appliances
- Integrated display with keypad
- NEMA 4 enclosure
- Listed to UL508
- Interlocks two appliances
- NEMA 4 enclosure
- Listed to UL508
- Interlocks one appliance
- Slide indicator for fan speed
- NEMA 1 enclosure
- Integrated display with keypad
- NEMA 1 enclosure













